# TEST REPORTS

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

| IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 23-12-2020 |
|---|---|

**Name of Work : Providing and Fixing LED lights at Yelahanka Division**

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 16-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 23-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | N/mm$^2$ | N/mm$^2$ |
| 1 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 455 | 15.5 | 15.12 |
| 2 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 465 | 15.2 | |
| 3 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 462 | 14.7 | |

Remarks :

Asst. Executive Engineer
Project Division
Yelahanka Zone
BBMP, Bangalore - 92

AARTN ASSOCIATES ★ ZONE ★ BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 23-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 16-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 23-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 463 | 14.95 | 15.17 |
| 2 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 473 | 15.25 | |
| 3 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 470 | 15.30 | |

Remarks :

BANGALORE * AARTN ASSOCIATES *

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 23-12-2020

## Name of Work: Providing and Fixing LED Lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 16-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 23-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 470 | 15.25 | 15.50 |
| 2 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 480 | 15.78 | |
| 3 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 473 | 15.47 | |

Remarks :

AARTN ASSOCIATES BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

| IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 23-12-2020 |
|---|---|

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 16-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 23-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | N/mm$^2$ | N/mm$^2$ |
| 1 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 460 | 15.32 | 15.55 |
| 2 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 471 | 15.46 | |
| 3 | Footing | M20 | 16-12-2020 | 23-12-2020 | 150x150x150 | 22500 | 457 | 15.86 | |

Remarks :

AARTN ASSOCIATES BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 24-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 17-12-2020 |
| Sample Type | C.C Road Top Layer |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 24-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in K.N | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 467 | 15.24 | 15.40 |
| 2 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 477 | 15.65 | |
| 3 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 464 | 15.32 | |

Remarks :

AARTN ASSOCIATES BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 24-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 17-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 24-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 466 | 14.80 | 15.23 |
| 2 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 476 | 15.25 | |
| 3 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 463 | 15.65 | |

Remarks :

AARTN ASSOCIATES DATE BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 24-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 17-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 24-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 473 | 14.10 | 14.66 |
| 2 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 483 | 14.56 | |
| 3 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 476 | 15.32 | |

Remarks :

AARTN ASSOCIATES BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 24-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 17-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 24-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 488 | 14.38 | 15.27 |
| 2 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 498 | 15.69 | |
| 3 | Footing | M20 | 17-12-2020 | 24-12-2020 | 150x150x150 | 22500 | 485 | 15.74 | |

Remarks :

AARTN ASSOCIATES BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 26-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 19-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 26-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 466 | 15.2 | 15.34 |
| 2 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 476 | 15.35 | |
| 3 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 469 | 15.46 | |

Remarks :

BANGALORE AARTN ASSOCIATES

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 26-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 19-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 26-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | N/mm$^2$ | N/mm$^2$ |
| 1 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 456 | 14.21 | 15.01 |
| 2 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 466 | 15.23 | |
| 3 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 452 | 15.60 | |

Remarks :

AARTN ASSOCIATES BANGALORE DATE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 26-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 19-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 26-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 455 | 14.23 | 15.23 |
| 2 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 462 | 15.85 | |
| 3 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 452 | 15.62 | |

Remarks :

AARTN ASSOCIATES BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 26-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 19-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 26-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 453 | 15.37 | 15.46 |
| 2 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 472 | 15.32 | |
| 3 | Footing | M20 | 19-12-2020 | 26-12-2020 | 150x150x150 | 22500 | 460 | 15.68 | |

Remarks :

AARTN ASSOCIATES BANGALORE

# AARTN ASSOCIATES

*The Modern Construction Solutions*

#1059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com


## Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) | Date: 28-12-2020

## Name of Work : Providing and Fixing LED lights at Yelahanka Division

| | |
|---|---|
| Client | Bruhat Bengalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru. |
| Contractor | Sri. Madhusudhan A N M/s Suraksha Electricals |
| Customer Reference | EE(PROJECT)/YNK ZONE/WO/89/2020-21 |
| Source of Sample | Sample supplied by Agency |
| Sample Condition | Satisfactory |
| Date of Reciept | 21-12-2020 |
| Sample Type | Footing |
| Sample Type/Size | 150x150x150 mm |
| Sample Grade/ Age | M20/ 7 Days Compressive Strength |
| Date of Test | 28-12-2020 |
| Location | |

| Sl No. | Identification Mark | Grade of Concrete | Date of Casting | Date of Trsting | Dimension of Specification | Cross sectional area | Maximum Load in | Compressive Strength | Average Compressive Strength |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | mm | Sq.mm | KN | $N/mm^2$ | $N/mm^2$ |
| 1 | Footing | M20 | 21-12-2020 | 28-12-2020 | 150x150x150 | 22500 | 463 | 14.23 | 14.47 |
| 2 | Footing | M20 | 21-12-2020 | 28-12-2020 | 150x150x150 | 22500 | 481 | 14.54 | |
| 3 | Footing | M20 | 21-12-2020 | 28-12-2020 | 150x150x150 | 22500 | 469 | 14.65 | |

Remarks :

AARTN ASSOCIATES BANGALORE